

NOTE A

CONCRETE TO BE CAST A MINIMUM OF 7 DAYS BEFORE INSTALLATION OF EQUIPMENT.
(GRADE 30/40 N/SQ mm)
BOTH FOUNDATIONS SHOULD BE SMOOTH, FLAT AND LEVEL WITH EACH OTHER.


INFILL OPTIONS

TUBE, BAR, MESH, PALISADE, ETC.

HANDING

GATE SHOWN IS RIGHT HAND.
LEFT HAND IS MIRROR IMAGE.

 PUSH BUTTON CONTROL

 CUSTOMER'S MAINS ISOLATER OR DISTRIBUTION BOARD
1Ph / 230V / 6A SUPPLY

